



February 8, 2011

Washington State Department of Ecology
Southwest Regional Office
PO Box 47775
Olympia, WA 98504

**RE: NPDES # WA-002666-2, MONTHLY REPORT, JANUARY 2011, ELWHA
WATER TREATMENT PLANT**

Attn: NPDES Data Entry Team

Enclosed is a copy of the monthly Discharge Monitoring Report (DMR) for the Elwha Water Treatment Plant (Port Angeles, WA) for the month of January 2011. The report is being submitted by Veolia Water North America (VWNA) Operating Services on behalf of the US Department of Interior, Bureau of Reclamation. A copy has been submitted to the Washington DOE. Signed originals of the DMR have been submitted to Region 10 EPA.

In addition to the monthly DMR for January 2011, an annual Receiving Water Monitoring Report is being submitted for 2010. The attached report covers the period from April 2010, when Veolia Water commenced operating the facility, through December 2010.

Please contact me if there are any questions or comments regarding the enclosed forms.

Sincerely,

A handwritten signature in dark ink, appearing to read "Michael S. Greene", written over a horizontal line.

Michael S Greene
District Manager

CC: Richard Bauman, BOR
Paul Rothgery, NPS
Jeff Bohman, NPS
Chris Lewis, NPS

Enclosures:

1. DMR, January 2011, EPA Form 3320-1 (4 pages)
2. 2010 Receiving Water Monitoring Report

PERMITTEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME US Department of Interior
Bureau of Reclamation
ADDRESS 826 East Front Street, Suite A
Port Angeles WA 98362-3613

FACILITY Elwha Water Treatment Plant
LOCATION Elwha River/ Lat: 48° 10' 10" N/Long: 123° 33' 7" W.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(12-16)	(17-19)
WA-002666-2	001
PERMIT NUMBER	DISCHARGE NUMBER

Sedimentation Plant (non-wastewater)

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2011	01	01		2011	01	31
	(20-21)	(12-23)	(24-31)		(26-27)	(28-29)	(30-31)

***** NO DISCHARGE | X | *****

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS	(38-45) MINIMUM	(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS				
Flow	SAMPLE MEASUREMENT				*****	*****	*****		0			
Influent	PERMIT REQUIREMENT	Report	Report	CFS						Continuous	Recording	
Flow	SAMPLE MEASUREMENT				*****	*****	*****		0			
Effluent	PERMIT REQUIREMENT	Report	Report	CFS						Continuous	Recording	
Turbidity	SAMPLE MEASUREMENT	*****	*****		*****				0			
Influent	PERMIT REQUIREMENT					Report	Report	NTU		Continuous	Recording	
pH	SAMPLE MEASUREMENT	*****	*****		*****				0			
Influent	PERMIT REQUIREMENT					6.5 - 8.5	8.5	s.u.		5/ week	Grab	
pH	SAMPLE MEASUREMENT	*****	*****		*****				0			
Effluent	PERMIT REQUIREMENT					6.5 - 8.5	8.5	s.u.		5/ week	Grab	
Temperature	SAMPLE MEASUREMENT	*****	*****		*****				0			
Influent	PERMIT REQUIREMENT					Report	Report	°C		5/Week	Grab	
Temperature	SAMPLE MEASUREMENT	*****	*****		*****				0			
Influent	PERMIT REQUIREMENT					Report	Report			5/Week	Grab	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY				TELEPHONE		DATE				
Michael S Greene, PE Project/Plant Manager, Veolia Water N. America Operating Services						360	417-1180	2011	02	08		
TYPED OR PRINTED		KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

The Elwha River WTP (Sedimentation) is currently in a "mothball" or stand-by operating mode. It is operated on an intermittent basis for commissioning and equipment exercise. There were no slurry discharges from 001.

Computer Reproduction EPA Form 3320-1

PERMITTEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME US Department of Interior
Bureau of Reclamation
ADDRESS 826 East Front Street, Suite A
Port Angeles WA 98362-3613

FACILITY Elwha Water Treatment Plant
LOCATION Elwha River/ Lat: 48° 10' 10" N/Long: 123° 33' 7" W.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)


(2-16)	(17-19)
WA-002666-2	001
PERMIT NUMBER	DISCHARGE NUMBER

Sedimentation Plant (non-wastewater)

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2011	01	01		2011	01	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

***** NO DISCHARGE [X] *****

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS	(38-45) MINIMUM	(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS			
Fecal Coliform Influent	SAMPLE MEASUREMENT	*****	*****		*****				0		
	PERMIT REQUIREMENT					Report	Report	#/100 ml		10/Month	Grab
Fecal Coliform Effluent	SAMPLE MEASUREMENT	*****	*****		*****				0		
	PERMIT REQUIREMENT					Report	Report	#/100 ml		10/Month	Grab
Total Suspended Solids Influent Daily Average Influent Turbidity > 50 NTU	SAMPLE MEASUREMENT				*****				0		
	PERMIT REQUIREMENT	Report	See I.B.3 & I.B.4	Lb/Day		Report	Report	mg/L		Daily	24-Hr composite
Total Suspended Solids Effluent Daily Average Influent Turbidity > 50 NTU	SAMPLE MEASUREMENT				*****				0		
	PERMIT REQUIREMENT	Report	See I.B.3 & I.B.4	Lb/Day		Report	Report	mg/L		Daily	24-Hr composite
Total Suspended Solids Influent Daily Average Influent Turbidity < 50 NTU	SAMPLE MEASUREMENT				*****				0		
	PERMIT REQUIREMENT	Report	22	#/CFS River		Report	Report	mg/L		Daily	24-Hr composite
Total Suspended Solids Effluent Daily Average Influent Turbidity ≤ 50 NTU	SAMPLE MEASUREMENT				*****				0		
	PERMIT REQUIREMENT	Report	22	#/CFS River		Report	Report	mg/L		Daily	24-Hr composite
Settleable Solids Influent	SAMPLE MEASUREMENT	*****	*****		*****				0		
	PERMIT REQUIREMENT					Report	Report	ml/L		1/month	24-Hr composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael S Greene, PE Project/Plant Manager, Veolia Water N. America Operating Services TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ANY ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION AND THAT I AM A QUALIFIED PERSON DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			360	417-1180	2011	02	08
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME US Department of Interior
Bureau of Reclamation
ADDRESS 826 East Front Street, Suite A
Port Angeles WA 98362-3613

FACILITY Elwha Water Treatment Plant
LOCATION Elwha River/ Lat: 48° 10' 10" N/Long: 123° 33' 7" W.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)
WA-002666-2
PERMIT NUMBER

(17-19)
001
DISCHARGE NUMBER

Sedimentation Plant (non-wastewater)

MONITORING PERIOD
FROM YEAR MO DAY TO YEAR MO DAY
2011 01 01 2011 01 31
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

***** NO DISCHARGE | X | *****

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS	(38-45) MINIMUM	(46-53) AVERAGE MONTHLY	(54-61) MAXIMUM DAILY	UNITS			
Settleable Solids	SAMPLE MEASUREMENT	*****	*****		*****				0		
Effluent	PERMIT REQUIREMENT					Report	Report	ml/L		1/month	24-Hr composite
BOD ₅	SAMPLE MEASUREMENT	*****	*****		*****				0		
Effluent	PERMIT REQUIREMENT					Report	Report	mg/L		1/month	24-Hr composite
Alkalinity	SAMPLE MEASUREMENT	*****	*****		*****			mg/L	0		
Effluent	PERMIT REQUIREMENT					Report	Report	as CaCO ₃			
Total Dissolved Solids	SAMPLE MEASUREMENT	*****	*****		*****				0		
Influent	PERMIT REQUIREMENT					Report	Report	mg/L		1/month	24-Hr composite
Total Dissolved Solids	SAMPLE MEASUREMENT	*****	*****		*****				0		
Effluent	PERMIT REQUIREMENT					Report	Report	mg/L		1/month	24-Hr composite
Total Aluminum	SAMPLE MEASUREMENT				*****				0		
Influent	PERMIT REQUIREMENT	Report	Report	lb/Day		Report	Report	mg/L		1/month	24-Hr composite
Total Aluminum	SAMPLE MEASUREMENT				*****				0		
Effluent	PERMIT REQUIREMENT	Report	Report	lb/Day		Report	Report	mg/L		1/month	24-Hr composite



NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael S Greene, PE Project/Plant Manager, Veolia Water N. America Operating Services TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS		360	417-1180	2011	02	08
			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME US Department of Interior
Bureau of Reclamation
ADDRESS 826 East Front Street, Suite A
Port Angeles WA 98362-3613

FACILITY Elwha Water Treatment Plant

LOCATION Elwha River/ Lat: 48° 10' 10" N/Long: 123° 33' 7" W.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

WA-002666-2

PERMIT NUMBER

(17-19)

001

DISCHARGE NUMBER

Sedimentation Plant (non-wastewater)

MONITORING PERIOD

FROM

YEAR

MO

DAY

TO

YEAR

MO

DAY

2011

01

01

2011

01

31

(20-21)

(22-23)

(24-25)

(26-27)


(28-29)

(30-31)

***** NO DISCHARGE | X | *****

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only)			QUALITY OR CONCENTRATION (4 Card Only)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53)	(54-61)	UNITS	(38-45)	(46-53)	(54-61)	UNITS			
		AVERAGE MONTHLY	MAXIMUM DAILY		MINIMUM	AVERAGE MONTHLY	MAXIMUM DAILY				
Dissolved Oxygen	SAMPLE MEASUREMENT	*****	*****		*****				0		
Influent	PERMIT REQUIREMENT					Report	Report	mg/L		1/Month	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

RECEIVED
FEB 14 2011
U.S. EPA REGION 10
OFFICE OF COMPLIANCE AND ENFORCEMENT

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.		TELEPHONE		DATE		
Michael S Greene, PE Project/Plant Manager, Veolia Water N. America Operating Services			360	417-1180	2011	02	08
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)